

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	Anantapur	7	174									
2	Kurnool	7	190									
3	Mahabubnagar	1	47									
4	Nalgonda	0	84									
5	Medak	3	76									
6	Ranga Reddy (S)	12	77									
7	Ranga Reddy(N)	40	133									
8	Ranga Reddy(E)	34	103									
9	Hyderabad	103	633	1	1	1	1	1	1			
	<b>Total</b>	<b>207</b>	<b>1517</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	Anantapur	55	515	1								Still
2	Kurnool	52	393	1		1		1				
3	Mahabubnagar	72	628									
4	Nalgonda	92	656		9		9		9			
5	Medak	57	587	1	2	1	2	1	2			
6	Ranga Reddy (S)	29	167									
7	Ranga Reddy(N)	6	40									
8	Ranga Reddy(E)	0	57									
	<b>Total</b>	<b>363</b>	<b>3043</b>	<b>3</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>0</b>	<b>0</b>	

<b>132KV Break downs</b>										
S.No	Name of 220/132KV SS	Name of 132 KV Feeder	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
	Nil									

**33KV Break downs**

S.No	Name of 132/33KV SS	Name of 33 KV Feeder	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
	<b>Anantapur</b>									
1	220kv Kalyandurg	33kv Nuthimadugu	Kalyandurg	17:50	Still	Still	Still		Batvanipalli Nuthimadugu	-
	<b>Kurnool</b>									
1	Dhone	Peapully	Dhone	12:30	14:30	2:00	E/L	33 kv pin binding cut at location no.63	Mallyala, kothaplli, peapully, Hussinapuram,, P.R.Palli	-
	<b>Medak</b>									
1	Pashamailaram	Manjeera	Sangareddy	7:10	9:15	2:05		B/D Due to JUMPER CUT	Manjeera	-
	<b>Hyd Central</b>									
1	132KV Hussain Sagar	Jawahar Nagar	H' Sagar	5:07	5:22	0:15	EL	Stick fallen on 33KV OH Line at Loc.No.21	Jawahar Nagar	Loads transferred onto 132KV Imlibun SS via 33KV King Koti at 9.26 hrs Loads normalised after removing fallen Stick on lines at Loc.No.21

**11KV Break downs**

S.No	Name of 33/11KV SS	Name of 11KV Feeder	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Areas Effected	Alternate Supply Arranged
	<b>Nalgonda</b>									
1	Maryia	Mailaram	Bhongir	12:20	12:50	0:30		HT/LT	Mailaram	-
2	Chada	NachariPET	Bhongir	6:40	12:30	5:50		Single phase DTR fail	NachariPET	-
3	Garidepally	Kalmaicheruvu	Huzurnagar	6:00	10:00	4:00		Due to 11KV Conductor snapped at Kalmalcheruvu	Kalmaicheruvu	-
4	Thadakamalla	Thadakamalla	Miryalaguda	0:00	7:40	7:40		11KV Conductor snapped	Thadakamalla	-
5	Matoor	Ragadapa	Miryalaguda	4:00	11:00	7:00		11KV Conductor snapped	Ragadapa	-
6	Malkapur	Malkapur Indl	Nalgonda	14:10	16:40	2:30		11KV Line cut	Malkapur Indl	-
7	Veliminedu	Veliminedu	Nalgonda	3:45	8:10	4:25		11KV Line cut	Veliminedu	-
8	S.V. College	S.V. College	Suryapeta	9:20	10:20	1:00		Jumper cut	S.V. College	-
9	Ch. Annaram	Garlabaigudem	Suryapeta	14:45	16:30	1:45		Jumper cut	Garlabaigudem	-
	<b>Medak</b>									
1	MEDINIPUR	BOPPAIPALLY	Siddipet	5:00	9:00	4:00		B/D Due to JUMPER CUT	BOPPAIPALLY	-
2	Sulthanpur	Sulthanpur(Agl)	Jogipet	15:20	16:00	0:40		B/D due to Conductor Snapped Bardigudem(V)	Sulthanpur(Agl)	-
	<b>Hyd North</b>									
1	Kundanbagh	Brahmanwadi	Erragadda	3:43	5:30	1:47	EL	Cable fault at Green Park Hotel	Brahmanwadi	-